

# IT-DUMPS Q&A

Accurate study guides, High passing rate!  
IT-dumps provides update free of charge in one year!

**Exam : 648-247**

**Title : Implementing Cisco  
Connected Physical  
Security 2 Exam (CCSP 2)**

**Version : Demo**

1. When a 24 VDC fail safe lock is being used to secure a door, how should power be supplied to the lock from the control source?

- A. connected +24 VDC directly to the lock
- B. connected +24 VDC through common and normally close
- C. connected +24 VDC through common and normally open
- D. connected +5 VDC binary control signaling

**Answer: B**

2. What are the three common methods that are used for authentication with an access control system.?

- A. badge card, key fob, and keypad PIN
- B. badge card, keypad PIN, and password
- C. something you know, something you have, and something you are
- D. something you know, something you have, and something you did

**Answer: C**

3. Refer to the exhibit.



One or more expansion modules is connected to the Cisco Access Gateway via a CAN bus. How should the CAN bus wires be connected after the last module in the chain?

- A. The CAN bus wires should be looped back to the Cisco Access Gateway.
- B. The CAN bus wires should be twisted together and tucked away.
- C. The CAN bus wires should be plugged into a Layer 2 Ethernet switch.
- D. The CAN bus wires should be terminated with a high-impedance resistor.

**Answer: D**

4. What are the four main components of a typical logical door?

- A. door, door knob, door jam, and hinges
- B. lock, reader, tailgate sensor, and motion detector
- C. lock, request to exit, door position switch, and swing arm
- D. lock, reader, request to exit, and door position switch

**Answer: D**

5. Cisco Physical Access Manager (Cisco PAM) is an appliance-based solution. The Cisco PAM 1.3.2 appliance is available on which of the following server platforms?

- A. CIVS-MSP-1RU-K9

- B. CPS-MSP-1RU-K9
- C. CPS-MSP-2RU-K9
- D. CIAC-PAME-1125-K9

**Answer: B**